Modelling and optimization of combined heat and power systems

Elnaz Abdollahi

Modelling and optimization of combined heat and power systems

Elnaz Abdollahi

A doctoral dissertation completed for the degree of Doctor of Science (Technology) to be defended, with the permission of the Aalto University School of Engineering, at a public examination held at the lecture hall K216 (Otakaari 4) of the school on 18 October 2019 at 12 noon.

**Aalto University
School of Engineering
Department of Mechanical Engineering
Energy Efficiency and Systems**

Supervising professor

Professor Risto Lahdelma, Aalto University, Finland

Thesis advisor

Professor Risto Lahdelma, Aalto University, Finland

Preliminary examiners

Professor Esa Vakkilainen, Lappeenranta University of Technology, Finland

Associate Professor Natasa Nord, Norwegian University of Science and Technology (NTNU), Norway

Opponent

Associate Professor Natasa Nord, Norwegian University of Science and Technology (NTNU), Norway

Aalto University publication series

DOCTORAL DISSERTATIONS 179/2019

© 2019 Elnaz Abdollahi

ISBN 978-952-60-8743-6 (printed)

ISBN 978-952-60-8744-3 (pdf)

ISSN 1799-4934 (printed)

ISSN 1799-4942 (pdf)

<http://urn.fi/URN:ISBN:978-952-60-8744-3>

Unigrafia Oy

Helsinki 2019

Finland

Author

Elnaz Abdollahi

Name of the doctoral dissertation

Modelling and optimization of combined heat and power systems

Publisher School of Engineering

Unit Department of Mechanical Engineering

Series Aalto University publication series DOCTORAL DISSERTATIONS 179/2019

Field of research Energy Technology

Manuscript submitted 13 June 2019

Date of the defence 18 October 2019

Permission for public defence granted (date) 20 August 2019

Language English

☐ **Monograph**

☒ **Article dissertation**

☐ **Essay dissertation**

Abstract

Combined heat and power (CHP) production is a prominent technique for producing heat and electric power in an integrated process. While the produced heat is used locally, for district heating or for industrial processes, the electricity can be transmitted over long distances by the grid. The advantage of CHP is much higher energy efficiency than separate heat and power production. Therefore, CHP offers also significant potential for reducing emissions. At the same time, the global trend of increasing intermittent renewable energy forms is leading to imbalance between power supply and demand. While CHP production is difficult to adjust for non-coincident heat and power demand, the flexibility of a CHP system can be improved by including also separate power and heat production plants. Energy storages and power transmission between multiple areas can also improve the system flexibility and provide economic benefits. Cost efficient operation of such CHP systems can be determined by optimization models.

This study presents optimization models for different CHP planning problems, with different time horizons (short to long-term), single area and multiple areas, and with heat storages, power storages, or both. Depending on which components are included to the model, dedicated decomposition-based techniques have been developed for solving each model efficiently. An integrated model is decomposed into sub-models including both local and multi-area models. The first model is a multi-period local CHP model with heat storage. This model is solved by a generic linear programming (LP) algorithm, but a special extreme point formulation is applied in the modelling. The second model is an hourly multi-area model. A two-phase decomposition method including local and network models is proposed to optimize hourly multi-area energy production with power transmission. The third model extends the decomposition model with power storages for long-term problems. Last, an iterative process based on decomposition method is developed to include also heat storages. To produce realistic test data, a method was developed to generate heat demand with proper spatial and temporal variation also for areas where hourly historical data is unavailable.

The models have been validated by comparison with existing solution techniques for different problem sizes and time horizons. The results indicate that developed methods have high accuracy and fast solution time for long-term problems that is useful in solving hourly large-scale energy systems including thousands of variables. The speed advantage of the decomposition method improves with model size. The methods can be used for long-term planning of CHP system operation to support investment decisions, and for simulating system extension.

Keywords Combined heat and power, Optimization, Linear programming, Power transmission, Energy storage.

ISBN (printed) 978-952-60-8743-6

ISBN (pdf) 978-952-60-8744-3

ISSN (printed) 1799-4934

ISSN (pdf) 1799-4942

Location of publisher Helsinki

Location of printing Helsinki **Year** 2019

Pages 118

urn <http://urn.fi/URN:ISBN:978-952-60-8744-3>

Tekijä

Elnaz Abdollahi

Väitöskirjan nimi

Sähkön ja lämmön yhteistuotannon mallitus ja optimointi

Julkaisija Insinööritieteiden korkeakoulu**Yksikkö** Konetekniikan laitos**Sarja** Aalto University publication series DOCTORAL DISSERTATIONS 179/2019**Tutkimusala** Energiatekniikka**Käsitteilyajan pvm** 13.06.2019**Väitöspäivä** 18.10.2019**Väittelyluvan myöntämispäivä** 20.08.2019**Kieli** Englanti☐ **Monografia**☒ **Artikkeliväitöskirja**☐ **Esseeväitöskirja****Tiivistelmä**

Yhdistetty sähkön ja lämmön tuotanto (CHP) on tekniikka jossa sähköä ja lämpöä tuotetaan integroidussa prosessissa. CHP-tuotannon etuna on huomattavasti parempi energiatehokkuus verrattuna sähkön ja lämmön erillistuotantoon. Siksi CHP on potentiaalinen tekniikka myös päästöjen vähentämiseksi. Tuuli- ja aurinkosähkön voimakas lisääntyminen hankaloittaa tuotannon ja kysynnän ajallista kohtaamista. Tämä vaikeuttaa erityisesti CHP-tuotannon suunnittelua silloin kun sähkön ja lämmön kysyntävaihtelu ei ajallisesti kohtaa. CHP-järjestelmän joustavuutta voidaan parantaa energiavarastojen ja sähkön siirtoverkon avulla, ja samalla saavuttaa taloudellisia säästöjä. Tällaisen monimuotoisten energijärjestelmien toimintaa voidaan suunnitella optimointimallien avulla.

Tässä tutkimuksessa on kehitetty optimointimalleja CHP-tuotannon suunnitteluongelmiin, jotka ovat erilaisia aikahorisontin pituuden (lyhyt-pitkä aikaväli), alueiden lukumäärän (yksi tai useampi), ja varastojen suhteen (lämpö- tai sähkövarastot vai molempia). Ongelmiin on kehitetty tehokkaita dekompositioon perustuvia ratkaisualgoritmeja. Dekompositiossa järjestelmän kokonaismalli pilkotaan eri tavoin osamalleiksi, jotka ratkaisemalla saadaan kokonaismallin ratkaisu. Yksin-kertaisin malleista on yhden alueen CHP-tuotantomalli, johon sisältyy lämpövarasto. Malli voidaan ratkaista yleisenä lineaarisen ohjelmoinnin (LP) mallina, mutta mallinnuksessa on sovellettu erityistä ekstreemipisteformulaatiota. Seuraava malli on tunnittainen usean alueen malli, johon sisältyy sähkön siirtoverkko. Mallin ratkaisemiseen on kehitetty kaksivaiheisen dekompositiotekniikka, jossa sovelletaan parametrissa LP-analyysia aluekohtaisesti ja muodostetaan analyysin tulosten perusteella usean alueen sähkön tuotannon ja siirron verkkoitehtävä. Kolmannessa mallissa tunnittainen malli on laajennettu pitkän aikavälin malliksi ottamalla verkkotehtävään mukaan aluekohtaiset sähkövarastot. Lopuksi mallia on laajennettu kattamaan aluekohtaiset lämpövarastot. Sähkö- ja lämpövarastojen optimomiseksi yhdes-ä sähkön siirtojen laajennettiin dekompositiotekniikkaa kolmannella dekompositiomallilla ja mallien välisellä iteratiivisella prosessilla.

Realistisen testidatan tuottamiseksi kehitettiin tekniikka, jossa kulutusennustemalleja hyödyntämällä voidaan tuottaa ajallisesti ja alueellisesti oikealla tavalla vaihtelevaa kaukolämmön kulutusdataa niillekin paikkakunnille, joilta ei ole todellista tuntipohjaista mittaustietoa saatavilla. Kehitetyt mallit on validoitu vertailemalla tuloksia aikaisempiin malleihin ja ratkaisuteknikoihin eri kokoisilla CHP-järjestelmillä ja vaihtelevan pituisilla aikahorisonteilla. Kehitetyt menetelmät ovat tarkkoja ja nopeita suurillakin tehtävillä. Menetelmiä voidaan soveltaa sekä CHP-järjestelmien pitkän aikavälin käytön suunnittelussa, että simuloimaan järjestelmän laajennuksia investointipäätösten tueksi.

Avainsanat Yhdistetty sähkön ja lämmön tuotanto, optimointi, lineaarinen ohjelmointi, sähkön siirto, energiavarastot

ISBN (painettu) 978-952-60-8743-6**ISBN (pdf)** 978-952-60-8744-3**ISSN (painettu)** 1799-4934**ISSN (pdf)** 1799-4942**Julkaisupaikka** Helsinki**Painopaikka** Helsinki**Vuosi** 2019**Sivumäärä** 118**urn** <http://urn.fi/URN:ISBN:978-952-60-8744-3>

Acknowledgements

First, I want to express my gratitude to my supervisor, Professor Risto Lahdelma, who gave me the opportunity to start my research and work on interesting topics. I am grateful for the support and guidance he provided to me. I learned from his visions during my research leading to solve my research problems quickly. I highly appreciate the pre-examiners Professors Esa Vakkinen and Natasa Nord for their efforts to review this thesis and give valuable comments and suggestions. This research started with STEEM project funded by Aalto Energy Efficiency research program, and continued with STORE project funded by academy of Finland in Aalto University. I would like to thank all my colleagues in Energy Efficiency and Systems group and co-authors, Doctors Haichao Wang, Behnam Zakeri and Samuli Rinne for their helpful collaborations and discussions during my doctoral research. I also appreciate Armin Narimanzadeh for introducing Aalto University to me.

I have not achieved this stage without scarifications of my family. My brother who gave me motivation to achieve my desires. My father who made this journey easier by his support, and my mother whose strength, resistance, and patience were always my inspirations. At the end, my husband Mehmet, whose support and encouragement during the last three years was a big motivation for me. His efforts in his research and work taught me valuable lessons with his attitude towards the professional life which gave me the insights and motivation to learn continuously.

Espoo, June 2019
Elnaz Abdollahi

Contents

Acknowledgements.....	2
List of Abbreviations and Symbols.....	5
List of Publications	7
Author's Contribution.....	9
1. Introduction.....	10
1.1 Background	10
1.2 Research problem	12
1.3 Earlier Studies.....	13
2. Research objective and structure	16
2.1 Research scope and objective	16
2.2 Research structure	16
3. Methods	19
3.1 Target energy system	19
3.2 Convex CHP optimization model.....	20
3.3 Local CHP optimization with heat storage	22
3.4 Integrated multi-area multi-period CHP model.....	23
3.5 Decomposition model with power storages.....	25
3.5.1 Hourly local CHP models	26
3.5.2 Parametric analysis of the local model.....	27
3.5.3 Generic network flow problem.....	27
3.5.4 Encoding the hourly local production and transmission problem	28
3.5.5 Multi-period multi-area power production, storage, and	
transmission model	29
3.6 Decomposition model with power and heat storages.....	30
3.6.1 Local multi-period CHP production and storage model.....	32
3.7 Heat demand forecast model.....	34
4. Results and discussion.....	37
4.1 Local optimization solution	37

4.2	Hourly decomposition model solution.....	38
4.3	Decomposition model validation with integrated model.....	41
4.3.1	Decomposition model with power storages.....	41
4.3.2	Decomposition model with power and heat storages.....	42
4.4	Solution time for long-term problems.....	43
4.4.1	Decomposition model with power storages.....	43
4.4.2	Decomposition model with power and heat storages.....	44
4.5	Solution time of network model with simplex algorithm.....	46
4.6	Unit productions.....	47
5.	Conclusions and future research.....	49
5.1	Conclusions	49
5.2	Future research.....	50
	References	52
	Publications.....	56

List of Abbreviations and Symbols

Abbreviations

CHP	combined heat and power
HOB	heat only boiler
LP	linear programming
MILP	mixed integer linear programming

Symbols

C	production cost (€)
P	power demand (MWh)
Q	heat demand (MWh)
c_j, p_j, q_j	production price, power generation, and heat production at characteristic point j (MWh)
x_j	variables used to encode convex combination of operating region
C_{ik}	power transmission price from area i to k (€/MWh)
y_{ik}	power transmission variable from area i to k (€/MWh)
η	efficiency
s_{in}^p, s_{in}^q	charge of power and heat to storage (MWh)
s_{out}^p, s_{out}^q	discharge of power and heat out of storage (MWh)
s^p, s^q	power and heat storage level
$s^{p,0}, s^{q,0}$	initial level of power and heat storage
c_a	transmission price (€/MWh)
y_a	power flow in arc a (MWh)
Y	capacity limit (MWh)
C^*	optimal costs of power production P_{prod} (€)

l	line segment of piecewise liner curves
L_i	number of line segments in production area i
c^l	marginal production costs (slope of line segment l) (€/MWh)
d_i	supply in node i (MWh)
P_{prod}^0	minimal power production (MWh)
$\dot{P}_{prod}$	combined power production and storage (MWh)
C^0	cost of minimal power production (€)
$x_{i,l}$	production in area i and line segment l (MWh)
$x_i^{q+,t}$	surplus variable for heat (MWh)
$x_i^{p-,t}$	slack variable for power (MWh)
C^{q+}	surplus variable price (€/MWh)
C^{p-}	slack variable price (€/MWh)

Superscripts and subscripts

t	time
N	set of areas or nodes
U_i	index set for production unit at area i
J_u	extreme characteristic points of production unit u
i, k	areas i and k
max	maximum
min	minimum
s	storage
in	charge into storage
out	discharge out of storage
A	set of arcs
$dest(a)$	arcs to node
$org(a)$	arcs from node
i_0	production node

List of Publications

This doctoral dissertation consists of a summary and of the following publications which are referred to in the text by their numerals.

- 1.** Abdollahi, Elnaz; Wang, Haichao; Rinne, Samuli; Lahdelma, Risto. 2015. Optimization of energy production of a CHP plant with heat storage. IEEE Green Energy and Systems Conference (IGESC), California, USA, November 24. pages 30-34. DOI: 10.1109/IGESC.2014.7018636.
- 2.** Abdollahi, Elnaz; Wang, Haichao; Lahdelma, Risto. 2016. An optimization method for multi-area combined heat and power production with power transmission network. Elsevier. Applied Energy, volume 168, pages 248–256. ISSN: 0306-2619. DOI: 10.1016/j.apenergy.2016.01.067.
- 3.** Abdollahi, Elnaz; Wang, Haichao; Lahdelma, Risto. 2019. Parametric optimization of long-term multi-area heat and power production with power storage. Elsevier. Applied Energy, volume 235, pages 802-812. ISSN: 0306-2619. DOI: 10.1016/j.apenergy.2018.11.015.
- 4.** Abdollahi, Elnaz; Lahdelma, Risto. Decomposition method for optimizing long-term multi-area energy production with heat and power storages, Submitted to Applied Energy in 2019, under review.

Author's Contribution

The author has performed all the research described in this dissertation with the support and guidance of supervisor Prof. Risto Lahdelma. Author developed models and algorithms, did data collection, and analysis. Prof. Risto Lahdelma gave instructions and perceptive suggestions on programming and technical modelling, and the papers have been reviewed and finalized based on his comments.

Paper 1: Optimization of energy production of a CHP plant with heat storage.

The author developed the model, validated the results with existing energy optimization software, and analysed the results. The manuscript was written by the author. Samuli Rinne provided part of the data. Dr. Haichao Wang and Prof. Risto Lahdelma read and commented on manuscript drafts.

Paper 2: An optimization method for multi-area combined heat and power production with power transmission network.

The author developed the algorithm of the model and solved the model with different scales. The speed and efficiency of the model was tested by author. The results and manuscript were written by the author. Dr. Haichao Wang and Prof. Risto Lahdelma read and commented on manuscript drafts.

Paper 3: Parametric optimization of long-term multi-area heat and power production with power storage.

The author developed the model algorithm and implemented the test runs. The author also analyzed results and prepared the manuscript. Dr. Haichao Wang and Prof. Risto Lahdelma read and commented on manuscript drafts.

Paper 4: Decomposition method for optimizing long-term multi-area energy production with heat and power storages.

The author developed model algorithm and collected data for solution. The test runs have been implemented by the author and results have been interpreted. The author wrote the manuscript. Prof. Risto Lahdelma read and commented on manuscript drafts.

1. Introduction

1.1 Background

High energy efficiency has always been an essential target of the International Energy Agency (IEA). The role of high energy efficiency has become even more pronounced after the introduction of climate and energy policy regulations to encourage replacing fossil fuels by renewable energy resources. The intermittency of many renewable energy forms is creating additional challenges on load balancing in energy systems. For environmental emission reduction, the European Commission adopted a climate and energy framework presented by European Commission. The framework has three targets for year 2030 and is in line with a long-term perspective by year 2050. The targets are cutting the emissions by 40% compared to 1990 levels, increasing share of renewable energy by 32%, and improvement in energy efficiency by 32.5% [1].

Combined heat and power (CHP) production is a sustainable way to reduce greenhouse gases. Combined generation utilizes almost 90% of fuel energy and saves energy by 15-40% compared to power-only plants and heat-only boilers (HOBs). Different types of fuel, such as waste and renewables can in addition to fossil fuels be used in CHP combustion technology. The seasonality of electricity demand is balanced by CHP regarding the intermittent production of renewable energies [2], [3]. While generating electric power using CHP production, the heat obtained as a byproduct can be used as steam in industrial processes, or for heating up water in a district heating network that supplies heating for buildings. Today, CHP provides 15% of heat and 10.5% of power production in Europe [4]. CHP saves 200 million tons of carbon emission per year. Studies show that least 20% of electricity and 25% of heat can be produced by CHP in Europe by 2030 [5]. In Finland, CHP produced 32% of domestic power production and 64% of district heat in 2017. The domestic power production covered 76% of power consumption and the remaining 24% was supplied by import from Nordic countries, Estonia and Russia [6].

Power market development and integration is in focus at both EU and national levels. The Nordic day-ahead market is one of the largest power markets in the world. The market trades power daily for delivery. The power is transmitted from surplus areas with lower production price, e.g. Norway and northern Sweden to deficit areas with higher prices and higher demand, e.g. southern Sweden and Finland through transmission grids with cross-border connections [7], [8]. The power market is encountering a tremendous change due to the European Commission targets. In national energy strategies, the focus is

mainly on climate target. However, a well-functioning power market and security of supply are challenging [9]. The intermittency of solar and wind power, and yearly variations in hydropower make it difficult to predict the availability of power. Promoting renewable electricity may have consequences related to adequacy of electricity and risks on security of power supply. In the Nordic electricity market, subsidizing renewable production causes low electricity price in the market that can lead to unprofitability of conventional generation capacity.

Decommissioning thermal power plants may cause insufficiency of production capacity and inability to respond to rapid variations in the balance between supply and demand. Thus, the flexibility of the power system may be lost. Security of supply must be considered in parallel to the growth of intermittent generation that leads to higher demand for regulating generation capacity. Reduced thermal production capacity also causes reduction in power system inertia, which increases the risk of large electricity system failures. If the energy system is not flexible enough to react fast to any imbalance between supply and demand, this imbalance is absorbed by the inertia of the system leading to change in the frequency of the power. Too large frequency change will cause a blackout. The need of flexibility increases by increasing wind power production. Based on the plan, there will be 22 GW wind power in the Nordic region by 2050. Decommissioning of condensing power plants in Finland and Denmark and nuclear power plants in Sweden increases the risk of power shortages. If this trend continues, it will affect the adequacy of supply during peak demand in the region as shown in Figure 1 [9]. Out of the Nordic countries, Finland has the most diverse production capacity with 29% nuclear power, 31% hydro and biomass, and 40% fossil fuels [10]. When the power price or demand is low, HOB plants produce heat instead of CHP plants. The low and volatile power price in Finland may lead to replacing some CHP plants with HOB plants by 2040 [7].

Figure 1. Forecast changes in power generation capacity in Nordic power markets [9]

1.2 Research problem

Fluctuating power production results from increasing intermittent renewable sources of power production. There are also high fluctuations in power demand in Scandinavian countries, such as Finland [10]. Energy storages and extension of power transmission are among technologies to improve the flexibility between power supply and demand. Condensing power generation is a main source of flexibility in the Finnish power market. Lack of flexibility in an imbalanced power system has its cost. CHP plants with heat storages can adjust heat production level to improve the flexibility of the power system. Moreover, the power market requires solutions for efficient power generation and transmission. An optimization model of day-ahead market simulates the electricity generation and transmission between areas using hourly supply and demand curves. Day-ahead optimization models determine short-term operation of power systems. However, the climate and energy framework addresses security of supply problems on medium or long-term. Optimization and planning models for medium or long-term simulate behavior and interactions of energy systems.

The heat and power production are coupled in a CHP plant, which is one source of complexity in the optimization problems. The utilization of the energy storages and power transmission between areas can improve the profitability of CHP plants. Storages enhance the flexibility of systems and save costs. During high power price and low heat demand, a heat storage allows a CHP plant to produce more power and store the obtained excess heat for later use. During high heat demand and low power price, CHP can decrease power production or shut down. The lacking heat can be produced by a HOB or alternatively heat can be drawn from storage. In both cases, coupling CHP with heat storages gives benefit [11]. A power storage also can improve the flexibility and efficiency of an energy system by storing power during low demand periods and discharging during peak demand periods and high power price. Power storages save costs and lower overall operational cost. Power transmission between market areas minimizes total production costs. Power can be produced in the area where marginal production costs are lower and transferred to the area with higher production costs.

The dynamic behavior of storages is another source of complexity, because storage operation at any time step may affect operation in the far future. For planning problems, the optimal operation of storages can be a challenging problem due to uncertainty about the future conditions. In addition to the improvement of efficiency by storage units, power transmission constraints also increase the complexity. Dependency between components requires solving operation of all units together. The objective in CHP system optimization is to minimize total production cost of the energy system with power transmission lines and storage units. The time horizon can be short-term, i.e. several hours or days, to medium and long-term, i.e. several months and a year or even longer. The long-term planning models include thousands of hourly models having a large number of variables. Large-scale problems require fast methods and efficient solvers to find the optimal solution in a reasonable time. In short term

problems, when the market situation changes rapid re-optimization is necessary. Long-term problems need to be solved fast, because sensitivity and robustness analyses require solving many different variants of the problem.

1.3 Earlier Studies

The complexity of the optimization problem depends on the shape of constraints and objective function. Minimizing convex objective function subject to convex constraints is easier than finding the optimal of non-convex problems. Assuming convex CHP model allows applying linear programming (LP) models and algorithms to minimize objective function [12]. The LP formulation can easily be extended to implement various kinds of analyses [13]. Study [13] represents an LP model for optimizing the capacity of a 100% renewable energy system of a building. A linear Power Simplex algorithm was developed to optimize long-term CHP operation [12]. The long-term model was decomposed into thousands of hourly models. The algorithm optimized the hourly model on average 52 times faster than tabular Simplex. An uncertainly analysis method was presented for non-linear systems [14]. They developed a linear model to reduce the computational time. The linear model could estimate good accuracy the performance of gas turbine system 200 times faster than the non-linear model.

Non-convex CHP problems arise from non-convex operating regions or considering unit commitment (off/on states of the plants). Non-convex problems are difficult to solve and have high computational time, and the optimal solution is also difficult to achieve [14], [15]. The non-convex CHP operating region can be divided into convex multi-regions and formulated and solved as a mixed integer linear programming (MILP) [15–21], by Lagrangian relaxation methods [21–24], or by heuristic techniques [25], [26]. A MILP model was developed for optimization of a power system [15]. They proposed a three-step iterative algorithm to solve multi-objective function to utilize clean energy maximally, to get higher economic benefit, and to control risks of the operation. The algorithm solved the problem faster than other algorithms and found better global optimum. Economic optimization of a multi-timescale power system was performed by a MILP model [16]. They considered costs of operation, power ramping and unit commitment, and formed piecewise linear costs curves. They estimated the ramping requirement in the power system using a multi-objective function including both reliability and economic benefits of the system. A MILP model was used to find optimal design of renewable power system for a remote island [17]. They compared a binary variable model with an iterative process without binary variables and the results indicated that the iterative process could solve faster with a near-optimal solution. The authors in [18] developed a MILP model to solve a non-convex CHP problem. The problem was decomposed into thousands of single hour sub-problems, and a merging algorithm was developed to simulate the multi-period problem. Numerical results using real data demonstrated the efficiency and accuracy of the method for medium-term problems. A MILP model was proposed for robust

optimization of CHP with heat storage with uncertainty of heat demand [19]. The simulation results for 24 hours managed the uncertainty and found a near-optimal solution. A mixed-integer nonlinear programming problem was reformulated into a sequence of MILP problems in study [20] to minimize levelized cost of heat and cooling production of a hybrid system. A MILP demand response model was formulated for optimal planning of an air separation unit considering day-ahead power prices [21]. They used a Lagrangian relaxation technique to reduce the computational time and to improve the operating costs. Results were reported for a three-day ahead time horizon.

A Lagrangian relaxation model was proposed for unit commitment of large-scale hydro-thermal problems [22]. They compared the results with a MILP model, and showed that the MILP model is competitive with Lagrangian relaxation on small to mid-size instances, while Lagrangian relaxation approach is preferable for large-scale instances when fast solution time is important. Economic optimization of CHP was solved by Lagrangian relaxation in [23]. They tested the model with three benchmark problems, and the result showed that the method can give global optimum for non-convex problems. Lagrangian relaxation was applied also for short-term production of a power system with transmission and environmental constraints considering unit commitment [24]. The problem was decomposed into sub-problems, and transmission and environmental constraints were solved by network programming algorithm. Numerical results proved the efficiency and high speed of the approach.

The unit commitment of a multi-period CHP problem was modeled by a heuristic method utilizing both Lagrangian relaxation and a linear relaxation [25]. The method improved the solution in both quality and time. A heuristic algorithm was applied to address CHP production planning with power ramp constraints [26]. Numerical results with realistic data indicated that the heuristic could produce an acceptable solution fast. Integration of renewable production in a market based multi-region model was investigated to estimate the impact of Germany's energy transition on electricity price in the power market [27]. The model considered power transmission between regions and was solved using historical data for one year with different scenarios.

A review study classified optimization of short-term CHP planning problems based on different aspects [28]. A review and a thorough comparison between 37 software tools for models of energy systems was presented in [29]. Many tools (such as EnergyPLAN, energyPRO, COMPOSE, BALMOREL, BCHP Screening, SIVAEL, etc.) can analyze CHP systems. EnergyPLAN [30] and energyPRO [31] have been used to validate LP models with energy storages [32], [33]. The software scales are different, ranging from a building to international energy systems. EnergyPLAN and energyPRO were used to assess the business and economic feasibility of a small district heating system of an island based on 100% renewable energy and including a heat pump with heat storage [34]. The tools were categorized based on different applications including planning optimization and scenario analysis. Some tools such as OSemOSYS [35] are based on LP methods, and have been employed for medium to long-term energy scenarios [36]. For solution of long-term problems, both quality

and time are critical, since there are thousands of variables in the model. A MILP model was developed for long-term power production optimization with transmission expansion planning in national level [37].

Based on literature, few studies address optimization of long-term problems for both heat and power sectors considering energy storages and transmission network together. The long-term optimization models provide efficient decision making tools and useful information for producers, investors, and market planners. The models are applicable to compare flexibility solutions for extension of energy systems by storage units and power exchange capacity. Different approaches studied benefits of heat and power storages [38–42].

2. Research objective and structure

2.1 Research scope and objective

Optimization of long-term models to ensure cost-efficient operation of energy systems and provide security of supply to consumers is the aim of this research. The models can optimize operational planning and investment decisions. Participants of the integrated power market can optimize the plant operations and power trade and balance their portfolios.

The main objective of this thesis is to develop models and optimization methods that can be used for solving complex CHP optimization problems fast. The main objective is divided into sub-tasks by considering different CHP system configurations of gradually increasing complexity. All considered models are convex in this study. This means that for example non-convex CHP plant characteristics and unit commitment of production plants are outside the scope of this study. Also, hydropower modelling has been excluded from this study.

2.2 Research structure

The models in this thesis determine optimal operation of heat and power production with minimal cost. All models minimize the production cost for both heat and power sectors and include different energy production units. Time steps of the models are hourly and can solve problems with different time horizons. The models can be applied for optimization of real life energy system, i.e. planning optimal local or multi-area CHP operation. Table 1 represents some aspects of the papers. The scale and duration time of the case studies, the analysis method, and the results are summarized in the table.

Table 1. Summary of the publications

	Paper 1	Paper 2	Paper 3	Paper 4
Scale	Local	Multi-area	Multi-area	Multi-area
Time horizon	Weekly	Hourly	Yearly	Yearly
Case study	A Finnish city	Sample case	Sample case	Finish cities
Software	LP2	LP2 and Network power simplex	LP2	LP2
Analysis	CHP optimization with heat storage with different capacities and power sale revenue	Decomposition method for large-scale problems to optimize multi-area CHP system	Decomposition method for long-term problems to optimize multi-area CHP system with power storage	Decomposition method based an iterative optimization of long-term multi-area CHP system with heat and power storages based on heat demand forecast
Results	<ul style="list-style-type: none"> - Improvement of the CHP production planning model with heat storage to provide detailed results e.g. fuel consumption. - Validation with EnergyPLAN and energyPRO. - Flexibility of the model to apply different kinds of technologies. 	<ul style="list-style-type: none"> - A decomposition method to solve large number of hourly production and transmission problems efficiently. - Fast solution of the model is applicable using network model for long-term CHP planning problems with thousands of hourly models. 	<ul style="list-style-type: none"> - Validation of the method by an integrated model. - Comparison of the solution time and optimal values with integrated model for different time horizons shows the accuracy and speed of the developed method. 	<ul style="list-style-type: none"> - Validation of the decomposition method shows the accuracy of a sub-optimal solution by 0.02% difference from the true optimum. - The method can solve much larger problems than an integrated model and speed advantage of the method improves dramatically with model size.

Paper 1: A model for optimization of heat and power production with a heat storage was developed. The revenue was maximized through selling power production to the market. It solved one city in Finland for one week using real heat demand data for different capacities of heat storages, and the results demonstrated the high efficiency of the model using two optimizers for energy problems.

Paper 2: A decomposition method was proposed to optimize energy systems for multi-area heat and power production. The power transmission was considered in the model, and the problem was decomposed into two optimization models: a local energy production model, and a network flow model. The model was solved for a four-region sample case for one hour. Moreover, solution time of large transshipment network flow problems with different sizes were tested using a network simplex algorithm against a sparse simplex algorithm.

Paper 3: The multi-area decomposition model was integrated with power storages to optimize long-term energy production. An integrated model was developed to validate the results. Both optimal production and solution time of the method were validated and compared by the integrated model for different time horizons. Numerical results showed that the solution speed of decomposition model with power storages is considerably faster than the integrated model. The global optimum has high accuracy in comparison with integrated model.

Paper 4: A three-phase iterative optimization method was developed to optimize the previous multi-area CHP production and power transmission model

extended with heat storages. In addition, a linear regression model was developed to forecast hourly heat demand based on temperature and social cycle, and this model was used to generate realistic demand data for multiple areas. The iterative algorithm can give sub-optimal solutions much faster than the integrated model and can also solve much larger models in terms of number of areas and length of time horizon.

Figure 2 illustrates the structure and connections between the papers and developed model applications.

Figure 2. An overview of paper structure and connections

Two types of models were developed: integrated models optimizing heat and power production as a single model, and decomposition models where the solution is obtained by solving multiple smaller models in separate phases. Paper 1 optimized CHP production with heat storage for a short-time horizon, one week. The LP model was validated by EnergyPLAN and energyPRO software. In parallel, the decomposition method was proposed to optimize multiple area energy production with power transmission in paper 2. Dynamic constraints were considered in paper 3. We included power storages to the model. The decomposition method was extended to optimize multi-period multi-area problem with power storages. The developed integrated model was used to validate the results for optimal total production costs and to assess the speed of optimization. Paper 4 considers heat storage in the decomposition model. The decomposition model optimized the CHP system using a three-phase iterative method. Both numerical result and solution time were compared with the integrated model for different size problems.

3. Methods

3.1 Target energy system

This study considers both local single-area and multi-area CHP system optimization. Figure 3 illustrates the general structure of the target energy system in each area. Different models may lack one or more of the components illustrated in the figure. For example, a single-area model does not include power transmission, but power transmission is an essential part of a multi-area model.

The system can include different kinds of production technology. CHP with heat pump can balance the power production. CHP plants, HOBs and heat pumps produce heat. Power is produced by CHP and power-only plants. Heat pumps and electric boilers also affect the power balance. During power shortage, CHP supplies power, and during excess power production, power is consumed by heat pump and possible electric heat boiler [43]. The power-only plants can include non-thermal power plants, such as solar power, wind power, and non-controllable hydropower, or thermal power plants, such as nuclear power, or combustion of fossil and bio-fuels. Controllable hydropower with water reservoir can in principle be modelled as a power storage filled spontaneously by rainfall, but we have not included in this study. Power can be transmitted between other areas, stored during low demand and discharged from the storage during peak demand. Heat cannot be distributed between areas, it is distributed only locally through a district heating network for residential use, or used by some industrial process as steam. This means that heat must be balanced locally. Besides adjusting the heat production using CHP, HOBs and heat pumps, storages store heat during low demand and discharge heat during high demand.

Figure 3. General CHP system configuration in each area.

3.2 Convex CHP optimization model

The following convex CHP model is used for modelling power and heat production in all subsequent models. The CHP operating region is formed by coordinates for power and heat production with corresponding costs. Costs consist mainly of fuel costs, but can also include fixed and variable operations and maintenance costs. The region can be considered as a surface in 3D space corresponding and it is defined by extreme characteristic points (p_j, q_j, c_j) . Figure 4 introduces a convex CHP operating region with the projection of power and heat on (p, q) plane. The projected (p, q) plane is a convex region, and the operating costs (c) is a convex function of p and q . Convexity of a region means that any line segment between two arbitrary points in the region is inside the region. Many types of CHP plants can be assumed convex. Convexity allows expressing an arbitrary point of the characteristic region as a convex combination (weighted average) of the extreme points. Such a convex combination is defined by linear constraints (1):

Figure 4. Convex operating region of a CHP plant.

$$\begin{aligned}
 C &= \sum_{j \in J_u} c_j x_j \\
 P &= \sum_{j \in J_u} p_j x_j \\
 Q &= \sum_{j \in J_u} q_j x_j \\
 \sum_{j \in J_u} x_j &= 1 \\
 x_j &\geq 0
 \end{aligned} \tag{1}$$

The index set J_u is used for the extreme characteristic points of the plant u . Non-negative variables x_j are applied to form the convex combination. Based on the formulation, the plant can run every point inside the 3D polyhedron spanned by the extreme points. However, the optimal solution with minimum cost is always at lower envelope surface of Figure 4. The lower envelope defines the minimum operating cost for each combination of power and heat production, including part-load operation. The characteristic point with maximum heat and power corresponds to maximum load operation.

Separate heat and power production plants can also be modelled by this technique. For power-only plants each $q_j = 0$ and for HOBs $p_j = 0$. Heat pumps consuming power and producing heat are represented by characteristic points where power is consumed and heat is produced ($p_j \leq 0, q_j \geq 0$). Also demand side management components for heat or power can be represented by this formulation.

Because all constraints of the convex CHP model (1) are linear, this model can be embedded as part of any LP model. In the following, different LP models are developed for optimizing the operation of different CHP system configurations. Dynamic CHP planning models are formulated as a multi-period LP model including a sequence of hourly models linked by different kinds of dynamic constraints. When the convex CHP model is embedded in multiperiod models, the characteristic points may remain constant over the planning horizon, or depend on the time index, e.g. to represent hourly changing fuel price, efficiency ratios, or maximum capacity. Also, switching a plant off for some hours can be represented operating at point (0,0,0), or alternatively setting the right hand side of the convexity constraint to zero.

3.3 Local CHP optimization with heat storage

This section presents an LP model to minimize *net acquisition costs* of a local CHP system with heat storage. This model was presented in Paper 1. A similar model was applied in [44] and for multi-criteria optimization of district heating system in [45]. The schematic of the model is introduced in Figure 5. This model is a subset of the general CHP system configuration in Figure 3 where the power storage and transmission are excluded and only one CHP production plant is included.

Figure 5. Schematic of the CHP plant by energyPRO [31]

The heat storage relaxes the connection between heat and power constraints. The CHP planning model composed out of hourly models, since the power market operates on hourly basis. The multi-period LP model is as follows:

$$\min \sum_{t=1}^T (\sum_{j \in J} c_j^t x_j^t - c_p^t P^t) \quad (2)$$

subject to

$$\sum_{j \in J} q_j^t x_j^t + \eta_{out}^q s_{out}^{q,t} - s_{in}^{q,t} = Q^t \quad (3)$$

$$\sum_{j \in J} p_j^t x_j^t = P^t \quad (4)$$

$$s^{q,t} = \eta_s^q s^{q,t-1} + s_{in}^{q,t} - s_{out}^{q,t} \quad (5)$$

$$\sum_{j \in J} x_j^t = 1 \quad (6)$$

$$0 \leq x_j^t \quad (j \in J) \quad (7)$$

$$0 \leq s^{q,t} \leq S^{q,max} \quad (8)$$

$$T = 1, \dots, T \quad (9)$$

Here objective function (2) minimizes the total net acquisition costs consisting of fuel costs (c^t) subtracted by revenue from power power sales ($c_p^t P^t$) to the spot market. Indices t and j correspond to time step and characteristic point of the CHP plant. Constraint (3) balances the heat production to satisfy heat demand Q^t using CHP heat production $q_j^t x_j^t$ with heat stored to storage ($s_{in}^{q,t}$) and discharged from storage ($s_{out}^{q,t}$) with discharge efficiency (η_{out}^q). The power sales (P^t) to the market is determined by power balance (4) at price c_p^t at each hour. The storage level ($s^{q,t}$) at the end of time step t in constraint (5) includes storage charge $s_{in}^{q,t}$ and discharge $s_{out}^{q,t}$ variables. The losses during storage is considered by the hourly storage efficiency factor η_s^q . Equations (6) and (7) represent convexity constraints for x_j^t variables. The capacity of storage is limited in (8).

The above formulation contains one CHP plant. The model can be easily extended to include multiple plants of different types. The model can be used for different purposes and solved for different planning horizons from short-term, to medium or long-term. The model can also be applied in investment planning for finding the ideal size of a heat storage, or for evaluating the benefit of a heat storage of given size.

3.4 Integrated multi-area multi-period CHP model

The most general CHP system considered in this study is obtained by composing a multi-area multi-period model from the CHP system presented in Figure 3. This model can contain different kinds of CHP, heat-only and power-only production plants, heat and power storages in different areas, and power transmission lines between areas. The system must be modelled as an integrated model, because CHP links power and heat together, storages links subsequent time steps (hour) together, and transmission network links multiple areas together.

The model optimizes energy production and storage in each area and power transmission between them. The model is an integrated general LP model minimizing total production and power transmission costs over the planning horizon. The problem is formulated as follows:

$$\min \sum_{t=1}^T \sum_{i \in N} \left(\sum_{u \in U_i} \sum_{j \in J_u} C_{u,j}^t x_{u,j}^t + \sum_{k \in N | k \neq i} C_{ik} y_{ik}^t + C^{q+} x_i^{q+,t} + C^{p-} x_i^{p-,t} \right) \quad (10)$$

s.t.

$$\sum_{u \in U_i} \sum_{j \in J_u} q_{u,j} x_{u,j}^t + \eta_{out,i}^q s_{out,i}^{q,t} - s_{in,i}^{q,t} - x_i^{q+,t} = Q_i^t \quad (11)$$

$$\sum_{u \in U_i} \sum_{j \in J_u} p_{u,j} x_{u,j}^t + \sum_{k \neq i} (y_{ki}^t - y_{ik}^t) + \eta_{out,i}^p s_{out,i}^{p,t} - s_{in,i}^{p,t} + x_i^{p-,t} = P_i^t \quad (12)$$

$$s_i^{q,t} = \eta_{s,i}^q s_i^{q,t-1} + \eta_{in,i}^q s_{in,i}^{q,t} - s_{out,i}^{q,t} \quad (13)$$

$$s_i^{p,t} = \eta_{s,i}^p s_i^{p,t-1} + \eta_{in,i}^p s_{in,i}^{p,t} - s_{out,i}^{p,t} \quad (14)$$

$$\sum_{j \in J_u} x_{u,j}^t = 1, \quad 0 \leq x_{u,j}^t \quad (15)$$

$$0 \leq x_i^{q+,t}, \quad 0 \leq x_i^{p-,t} \quad (16)$$

$$s_i^{q,0} = s_i^{q,T_{max}}, \quad s_i^{p,0} = 0$$

$$0 \leq s_i^{q,t} \leq s_i^{q,max}, \quad 0 \leq s_i^{p,t} \leq s_i^{p,max}$$

$$0 \leq s_{in,i}^{q,t} \leq s_{in,i}^{q,max}, \quad 0 \leq s_{in,i}^{p,t} \leq s_{in,i}^{p,max}$$

$$0 \leq s_{out,i}^{q,t} \leq s_{out,i}^{q,max}, \quad 0 \leq s_{out,i}^{p,t} \leq s_{out,i}^{p,max}$$

$$0 \leq y_{ik}^t \leq Y_{ik}^t \quad (k \in N \mid k \neq i)$$

The objective function (10) minimizes total operative costs including production cost $C_{u,j}^t x_{u,j}^t$ at extreme points j and transmission costs $C_{ik} y_{ik}^t$ along all transmission lines in each hour t . Index u refers to production units and the characteristic points of the units are indexed by j . Vector $x_{u,j}^t$ contains the hourly decision variables for unit u . Transmission costs depend on the power transmission y_{ik}^t from area i to area k in time step t with price C_{ik} . Surplus variables $x_i^{q+,t}$ allow disposal of excess heat production with price C^{q+} ($= 0$, if excess heat production can be freely disposed). Slack variables $x_i^{p-,t}$ allow producing extra production with price C^{p-} . The price of excess power production is higher than other unit productions. It means that it applies when other units cannot produce enough power.

In constraints (11)-(16), the free indices are implicitly quantified: time index $t = 1, \dots, T$ (periods in the time horizon), $i \in N$ (set of areas), and $u \in U_i$ (set of production units in area i). The heat balance (11) states that heat production $q_{u,j} x_{u,j}^t$, minus charging the storage by $s_{in,i}^{q,t}$ plus discharge from storage $s_{out,i}^{q,t}$ with an efficiency $\eta_{out,i}^q$ must match the local heat demand Q_i^t . The surplus variable allows disposal of excess heat production. Power balance constraints (12) state that the power production together with power transmission and storage operation must meet power demand P_i^t in each hour t and area i . Variables y_{ki}^t denote power transmission from area k to area i in hour t . Variable $s_{out,i}^{p,t}$ denote discharge of power from the storage with efficiency $\eta_{out,i}^p$ and $s_{in,i}^{p,t}$ denotes charging the storage. Constraints (13) and (14) determine the level of heat and power storages $s_i^{q,t}$ and $s_i^{p,t}$ at hour t in area i . Hourly heat and power storage efficiencies are defined by parameters $\eta_{s,i}^q$ and $\eta_{s,i}^p$. Charge efficiencies for heat and power correspond to $\eta_{in,i}^q$ and $\eta_{in,i}^p$. Convexity constraints for all

production units are defined in (15). Constraints (16) define bounds for all other variables. The initial level of heat storage is set to the level of storage in the last time step and power storage to zero. The transmission line capacities are defined by parameters Y_{ik}^t .

The integrated model becomes very large and slow to solve with many areas, production units, and time periods. For example, consider an 8-area yearly (8760 h) model where each area has one CHP plant with 3 characteristic points and one HOB with 2 characteristic points, a power and heat storage, transmission to the other 7 areas. Including the power slack and heat surplus variables, the number of decision variables is $8760 \times 8 \times (3+2+7+6+2) = 1\,401\,600$. The number of constraints is 420 488 plus 911 040 upper bounds for variables. Zero lower bounds for variables are handled implicitly by LP software, but upper bounds are treated either as constraints, or more efficiently using the upper bound technique. The large size of long-term multi-area CHP models is the reason why we have developed various decomposition methods such models faster.

3.5 Decomposition model with power storages

In this section, we consider the multi-area CHP problem without heat storages. We decompose the integrated model with power storages and power transmission into sub-models, and solve them in sequence. The decomposition method optimizes long-term models faster than the integrated model. The decomposition method includes two sub-models:

1. Hourly local CHP models
2. Multi-period multi-area power production, storage and transmission network model

Figure 6 shows the two-phase solution technique of the method. In the first phase, hourly local CHP optimization models consider a single area i and an hour t at a time. The models are obtained by removing power transmission and storages from the integrated model. Given local heat demand, the hourly models are analyzed using parametric LP analysis. Parametric analysis determines the optimal production cost as a function of power production for each hour and each area. Then, in the second phase, the functions are combined with power transmission and storage constraints and encoded into a multi-period multi-area network model. The network model is a power-only model, since the heat production has been solved in the first phase. The model defines optimal power production, transmission, and storage operation.

Figure 6. Flowchart of the two-phase decomposition model

3.5.1 Hourly local CHP models

Hourly local CHP models optimize production of power and heat production for a single area and a single hour, without storages or power transmission. The production cost is minimized based on given heat demand. Power production is a variable parameter in this model. The results of the following model are production costs as a function of power production for the area and hour. For each hour t and area i we have the model:

$$\min \sum_{u \in U_i} \sum_{j \in J_u} C_{u,j}^t x_{u,j}^t + C^{q+} x_i^{q+,t} + C^{p-} x_i^{p-,t} \quad (17)$$

s.t.

$$\sum_{u \in U_i} \sum_{j \in J_u} q_{u,j} x_{u,j}^t - x_i^{q+,t} = Q_i^t \quad (18)$$

$$\sum_{u \in U_i} \sum_{j \in J_u} p_{u,j} x_{u,j}^t + x_i^{p-,t} = P_{prod,i}^t \quad (19)$$

$$\begin{aligned} \sum_{j \in J_u} x_{u,j}^t &= 1, \quad 0 \leq x_{u,j}^t, \quad u \in U_i \\ 0 &\leq x_i^{q+,t}, \quad 0 \leq x_i^{p-,t} \end{aligned} \quad (20)$$

The objective function (17) minimizes the total production costs of all units u in the area. In the objective function, terms $C_{u,j}^t x_{u,j}^t$ refer production costs of unit u . As in the integrated model, surplus and slack variables contribute to costs $C^{q+} x_i^{q+,t}$ and $C^{p-} x_{sl,i}^{p-,t}$. Constraints (18) balance the local heat demand Q_i^t with heat production in the area by production at plants $q_{u,j} x_{u,j}^t$ and disposal of possible extra heat $x_i^{q+,t}$. Constraints (19) balance power production by production $p_{u,j} x_{u,j}^t$ and slack variable with local power production $P_{prod,i}^t$. Con-

straints (20) are the convexity constraints for all plants and non-negativity constraints for surplus and slack variables.

3.5.2 Parametric analysis of the local model

Parametric LP analysis of the model (17)-(20) defines the optimal production cost as a function of power production $P_{prod,i}^t$ for the area. The production cost function is a piecewise linear convex function $C_i^{*,t} = C(P_{prod,i}^t)$, since the model is an LP model. The function is represented by a sequence of $L_i^t + 1$ points $[(C_i^{t,0}, P_{prod,i}^{t,0}), \dots, (C_i^{t,L_i^t}, P_{prod,i}^{t,L_i^t})]$. The points are the corner points the piecewise linear convex function, and the line segments between them correspond to different basic LP solutions. The minimum possible of power production is $P_{prod,i}^{t,0}$ and the maximum possible production is $P_{prod,i}^{t,L_i^t}$. The slope of each line segment determines the marginal production cost for the corresponding range of power production. The marginal production cost in area i for line segment l is:

$$c_i^{t,l} = (C_i^{t,l} - C_i^{t,l-1}) / (P_{prod,i}^{t,l} - P_{prod,i}^{t,l-1}) \quad (21)$$

Piecewise linear cost functions are illustrated in Figure 11 (section 4.2). The line segments are encoded as arcs in the network model described in the next section. Substituting local power production $P_{prod,i}^t$ in (19) into (12) and considering power transmission gives:

$$P_{prod,i}^t = P_i^t - \left(\sum_{k \neq i} (y_{ki}^t - y_{ik}^t) + \eta_{out,i}^p s_{out,i}^{p,t} - s_{in,i}^{p,t} \right) \quad (22)$$

The hourly local optimization models link to the network model by equation (22). The network model described in the following sections.

3.5.3 Generic network flow problem

We present the *general network flow problem*, which is used later in decomposition modelling. A network flow model connects a set of nodes N by a set of directed arcs A . Non-negative amounts of a commodity can flow between the nodes along the arcs. Each arc $a \in A$ is associated with a unit cost c_a per amount of flow y_a . The network flow model minimizes the total cost of all flows while balancing the supply or demand at each node. Each node has a local supply or demand d_i . Supply is represented by a positive value d_i and demand by a negative value. The supply (demand) of each node must match the sum of outflows minus the sum of inflows. There can be capacity limits Y_a for arcs, and gains or losses η_a for the flows. The general network flow model is formulated as [46]:

$$\begin{aligned} & \min \sum_{a \in A} c_a y_a \\ & \text{s.t.} \end{aligned} \quad (23)$$

$$\sum_{a \in A | \text{org}(a)=i} y_a - \sum_{a \in A | \text{dest}(a)=i} \eta_a y_a = d_i, i \in N$$

$$0 \leq y_a \leq Y_a, a \in A$$

This model is a special case of an LP model. If all gains/losses $\eta_a = 1$, the model simplifies into the standard transshipment flow model with capacity limits. Then the problem is also called a *pure network flow problem*. Because no commodity is lost or gained in the pure network problem, the sum of all supplies and demands must equal zero, i.e. $\sum d_i = 0$. This makes the set of constraints linearly dependent, and one of the constraints (for an arbitrary node) can be removed. When the network contains gains or losses, to guarantee the existence of a solution one of the nodes is defined as an *open node*, and corresponding constraint is removed.

The advantage with network problem formulations is that there are very efficient algorithms for solving them; e.g. the Generalized Network Simplex algorithm [46] for the general network flow problem, and the Network Simplex algorithm [47] for capacitated transshipment flow problems.

3.5.4 Encoding the hourly local production and transmission problem

Here we present how to encode the parametric cost functions from the hourly local CHP models into a network flow problem for optimizing multi-area power production and transmission for a single hour. Each production area corresponds to a node with power demand or supply. Transmission lines between areas corresponds to transmission arcs with a capacity Y_a and cost c_a^t . Transmission costs can represent the small losses in transmission lines, i.e. cost for extra power production to compensate the loss. Thus, the transmission problem follows the capacitated transshipment flow model.

Then, the piecewise linear cost functions representing local power production in each area are combined with the hourly transmission problem. The local power demand in each area i and is defined as a sink node with negative demand $d_i^t = -P_i^t$ in which P_i^t is the demand. For supply, we create an artificial production node i_0^t with supply $d_{i_0}^t = \sum_i P_i^t$. Next, we define production arcs from production node to the area nodes. The lengths of parametric line segments determine the capacities of the production arcs equal to $(P_{prod,i}^{t,l} - P_{prod,i}^{t,l-1})$ and the slopes of line segments ($c_i^{t,l}$) determine the costs of production arcs. The network flow model is then formulated as:

$$\min \sum_{a \in A} c_a^t y_a^t + \sum_{i \in N} (C_i^{t,0} + \sum_{l=1}^{L_i} c_i^{t,l} x_i^{t,l}) \quad (24)$$

$$\sum_{a \in A | \text{org}(a)=i} y_a^t - \sum_{a \in A | \text{dest}(a)=i} y_a^t - \left(P_{prod,i}^{t,0} + \sum_{l=1}^{L_i} x_i^{t,l} \right) = -P_i^t \quad (i \in N) \quad (25)$$

$$\sum_{i \in N} \left(P_{prod,i}^{t,0} + \sum_{l=1}^{L_i} x_i^{t,l} \right) = \sum_{i \in N} P_i^t \quad (\text{redundant}) \quad (26)$$

$$\begin{aligned}
0 \leq x_{i,l}^t &\leq P_{prod,i}^{t,l} - P_{prod,i}^{t,l-1} \quad (i \in N) \\
0 \leq y_a^t &\leq Y_a \quad (a \in A)
\end{aligned} \tag{27}$$

The minimum possible power production of each area and corresponding minimum production cost ($P_{prod,i}^{t,0}, C_i^{t,0}$) are constants and must be factored out of the model and considered after solving the model. Because the set of constraints is linearly dependent, one of the constraints can be removed. We remove constraint (26), which is the balance constraint for the production node.

3.5.5 Multi-period multi-area power production, storage, and transmission model

In the absence of storages, the hourly models (24)-(27) can be solved independently. Including storages links the hourly models together by dynamic constraints. Here, we formulate a multi-period multi-area model with power storages as extension of the previous network model by combining the different hourly models together with power storage constraints. The model determines optimal production with power storages and transmission between areas.

The set of nodes N is formed from the area nodes for each hour. To simplify notation, we also include the production nodes i_0 the set of nodes N . Similarly, we form the set of arcs A as the union of all transmission and production arcs for each hour. Correspondingly, the arc costs c_a^t include both production costs and transmission costs, and similarly capacities Y_a^t include the maximum capacities for production arcs and transmission arcs. After adding storage constraints, we obtain the multi-period multi-area power transmission problem with storages:

$$\min \sum_{t=1}^T \sum_{i \in N} (C_i^{t,0} + \sum_{a \in A} c_a^t y_a^t) \tag{28}$$

s.t.

$$\sum_{a \in A | \text{org}(a)=i} y_a^t - \sum_{a \in A | \text{dest}(a)=i} y_a^t + s_{in,i}^{p,t} - \eta_{out,i}^p s_{out,i}^{p,t} = P_{prod,i}^{t,0} - P_i^t \tag{29}$$

$$s_i^{p,t} = \eta_{s,i}^p s_i^{p,t-1} + \eta_{in,i}^p s_{in,i}^{p,t} - s_{out,i}^{p,t} \tag{30}$$

$$\begin{aligned}
s_i^{p,0} &= 0 \\
0 \leq s_i^{p,t} &\leq s_i^{p,max} \\
0 \leq s_{in,i}^{p,t} &\leq s_{in,i}^{p,max} \\
0 \leq s_{out,i}^{p,t} &\leq s_{out,i}^{p,max} \\
0 \leq y_a^t &\leq Y_a^t
\end{aligned} \tag{31}$$

Objective function (28) minimizes total production and transmission costs for the selected time horizon. The total costs consist of a constant term for the minimum production $C_i^{t,0}$ in each area and power production and transmis-

sion costs $c_a^t y_a^t$. Power flow through transmission line or production arcs is represented by decision variables y_a^t with prices c_a^t and capacities Y_a^t . Power flow is balanced in constraint (29) for each area. The difference between $P_{prod,i}^{t,0}$ and the local demand equals to net amount of outflow from the area plus storage charge minus power discharge from storage with discharge efficiency $\eta_{out,i}$. Constraint (30) determine the level of power storage in each time step with storage efficiency $\eta_{s,i}^p$ and charge efficiency $\eta_{in,i}^p$. Constraints (31) defines initial power storage level and the upper bounds for all variables.

This network model is power-only. Because heat production was already optimized when computing the parametric cost curves included in this model, the network model solves the overall multi-period multi-area CHP system with power transmission and power storages (but without heat storages).

3.6 Decomposition model with power and heat storages

The previous model was unable to handle heat storages. In the following, we extend the model with heat storages and develop a decomposition method for solving the model. In addition to the two models in the previous section, we use local multi-period CHP models to optimize the heat storage operation in each area. The model (28)-(31) outputs optimal power production $P_{prod,i}^t$, power transmission and storage. Based on the network model, we compute for each area the combined power production and storage operation $\dot{P}_{prod,i}^t$:

$$\dot{P}_{prod,i}^t = P_{prod,i}^t + \eta_{out,i}^p s_{out,i}^{p,t} - s_{in,i}^{p,t} = P_i^t - \sum_{k \neq i} (y_{ki}^t - y_{ik}^t) \quad (32)$$

Alternatively, this quantity represents local demand subtracted by optimal power transmission determined by the network model. These quantities are provided as input for the local multi-period CHP models. This gives flexibility for the local multi-period models to re-optimize between power production and operation of power and heat storages.

The decomposition method for solving the problem with heat storages is applied iteratively. In each iteration, three kinds of sub-models are solved in sequence:

1. Hourly local CHP models
2. Multi-period multi-area power production, storage and transmission model (network flow model)
3. Local multi-period CHP production and storage models

The first two sub-models were explained earlier. Figure 7 outlines the iteration loop of the process. In each iteration, three sub-models are solved in sequence, and they provide input for each other. Dashed lines show output from each phase.

In the first phase, the hourly local models (17)-(20) determine optimal power production costs as a function of power production in areas $i = 1$ to N for selected time horizon $t = 1$ to T . The functions are based on hourly local heat demand. The cost functions are input for the second phase.

In the second phase, the multi-period multi-area model with power storages combine the cost functions for all areas and hours with power transmission and storages. The network model defines optimal power production, storage and transmission in each area. The model determines power production and transmission. The hourly combined power production and storage $\dot{P}_{prod,i}^t$ from (32) for the area is used in the third phase.

In the third phase, the multi-period local models optimize the power and heat production with storage operation using the results of network model. The optimal heat storage operation is used to provide input for the first phase model. The hourly heat storage discharge and charge modifies the hourly local heat demand of the models in the first phase.

The solution improves monotonically in each iteration by the three models. The algorithm stops, when the improvement is zero or small enough after the second or third model. The result is a sub-optimal total cost. In the second iteration, the hourly local model updates the power production cost functions and re-optimizes the multi-area model results. When the improvement is zero or small enough after the second or third phase models, the algorithm stops with a sub-optimal total production cost. In the following, the third phase local multi-period model is explained.

Figure 7. Flowchart of the iteration for decomposition model with power and heat storages

3.6.1 Local multi-period CHP production and storage model

The local multi-period CHP production and storage model optimizes heat storage operation using the combined power production and storage $\hat{P}_{prod,i}^t$. This model is obtained from the integrated model (10)-(16) by excluding power transmission constraints, whereby independent local models are obtained for each area. The local multi-period model formulation is

$$\min \sum_{t=1}^T \left(\sum_{u \in U_i} \sum_{j \in J_u} C_{u,j}^t x_{u,j}^t + C^{q+} x_i^{q+,t} + C^{p-} x_i^{p-,t} \right) \quad (33)$$

s.t.

$$\sum_{u \in U_i} \sum_{j \in J_u} q_{u,j} x_{u,j}^t + \eta_{out,i}^q s_{out,i}^{q,t} - s_{in,i}^{q,t} - x_i^{q+,t} = Q_i^t \quad (34)$$

$$\sum_{u \in U_i} \sum_{j \in J_u} p_{u,j} x_{u,j}^t + \eta_{out,i}^p s_{out,i}^{p,t} - s_{in,i}^{p,t} + x_i^{p-,t} = \dot{P}_{prod,i}^t \quad (35)$$

$$s_i^{q,t} = \eta_{s,i}^q s_i^{q,t-1} + \eta_{in,i}^q s_{in,i}^{q,t} - s_{out,i}^{q,t} \quad (36)$$

$$s_i^{p,t} = \eta_{s,i}^p s_i^{p,t-1} + \eta_{in,i}^p s_{in,i}^{p,t} - s_{out,i}^{p,t} \quad (37)$$

$$\sum_{j \in J_u} x_{u,j}^t = 1, \quad 0 \leq x_{u,j}^t \quad (38)$$

$$0 \leq x_i^{q+,t}, \quad 0 \leq x_i^{p-,t}$$

$$\begin{aligned} s_i^{q,0} &= s_i^{q,T_{max}}, \quad s_i^{p,0} = 0 \\ 0 &\leq s_i^{q,t} \leq s_i^{q,max}, \quad 0 \leq s_i^{p,t} \leq s_i^{p,max} \\ 0 &\leq s_{in,i}^{q,t} \leq s_{in,i}^{q,max}, \quad 0 \leq s_{in,i}^{p,t} \leq s_{in,i}^{p,max} \\ 0 &\leq s_{out,i}^{q,t} \leq s_{out,i}^{q,max}, \quad 0 \leq s_{out,i}^{p,t} \leq s_{out,i}^{p,max} \end{aligned} \quad (39)$$

Objective function (33) minimizes total costs including production costs $C_{u,j}^t x_{u,j}^t$, surplus variable cost $C^{q+} x_i^{q+,t}$, and slack variable cost $C^{p-} x_i^{p-,t}$. Heat balance constraint (34) supplies local heat demand Q_i^t with heat production $q_{u,j} x_{u,j}^t$ and discharge of the heat from storage $s_{out,i}^{p,t}$ minus heat charge into the storage $s_{in,i}^{q,t}$ and heat disposal $x_i^{q+,t}$. Power balance constraint (35) includes power production $p_{u,j} x_{u,j}^t$, power slack $x_i^{p-,t}$, and power discharge from storage $s_{out,i}^{p,t}$ minus the power charge into the storage $s_{in,i}^{p,t}$. This is equal to the combined power production and storage operation $\dot{P}_{prod,i}^t$. The storage levels are defined in constraints (36) and (37). Constraints (38) are the convexity constraints for production plants. Constraints (39) determine initial heat and power storage levels and the maximum capacities for storage variables.

The model determines power and heat production with storage operation for each area with fixed power transmission from the network model. The value of objective function (33) for all areas plus the total power transmission cost $\sum_{a \in A} c_a^t y_a^t$ from (28) gives the total cost. When the total cost improvement after solving this model is zero or small between iterations, the algorithm terminates. Otherwise, the optimal heat storage operation determined by this model is used in the first phase to re-optimize the parametric cost functions. The production of each unit can be computed from the solution of the local multi-period model by:

$$\sum_{j \in J_u} q_{u,j} x_{u,j}^t = Q_{u,j}^t \quad (40)$$

$$\sum_{j \in J_u} p_{u,j} x_{u,j}^t = P_{u,j}^t \quad (41)$$

3.7 Heat demand forecast model

To test the efficiency of the multi-period multi-area CHP models, it is necessary to use realistic test data. While yearly overall district heat demand data is available for all Finnish cities, unfortunately we obtained hourly demand data only for three cities. For this reason, we had to generate hourly heat demand data artificially. To make the heat demand data as realistic as possible, the heat demand of different cities should exhibit appropriate dependency of outdoor temperature, follow the social cycle, and show realistic random variation with proper coincidence across cities. For this reason, we present a method to generate realistic heat demand data for different geographical locations by using a heat demand forecasting model.

We apply a simple forecasting model that explains the heat demand by outdoor temperature and social cycle. There is a linear dependency between outdoor temperature and heat demand when the temperature is lower than 17°C, but no dependency at higher temperatures. When outdoor temperature is over this limit, no space heating is needed. Figure 8 displays the dependency between historical heat demand with outdoor temperature of a Finnish city in 2017. We use a linear regression model to estimate this dependency based on one year historical temperature information and heat demand for three cities.

Figure 8. Historical hourly heat demand of a city with outdoor temperature

The social cycle is mainly due to hot water usage in buildings. There is a daily cycle depending on when people wake up, wash, cook, and go to bed, and a weekly cycle, due to different schedules on weekdays and weekends. To repre-

sent the social cycle we form a 72 h weekly rhythm model. The week is divided into three kinds of days: working days, Saturdays, and Sundays. Every hour t within the year is then classified by an index $h(t)$ such that the hour within the day (1-24) is given for working days, Saturdays use indices 25-48, and Sundays 49-72. Special mid-week holidays are classified either as Saturdays or Sundays, because their social cycle differs from working days. The two different social cycles of 72 h and 168 h were compared in [48], and they were found to yield almost identical results. To prevent overfitting, we decided to use the 72 hour cycle. The linear regression model to forecast the heat demand is in the form of

$$y_t = x_t\beta + \beta_{h(t)} + \varepsilon_t \quad (42)$$

where y_t is the heat demand, x_t is the outdoor temperature, β is the coefficient for temperature dependency, $\beta_{h(t)}$ are the constants depending on the hour classification (1-72), and ε_t is hourly error (noise) in the equation. Instead of the actual outdoor temperature, x_t is the minimum of the actual temperature and 17°C. Linear regression determines the regression parameters ($\beta, \beta_{h(t)}$) so that the square sum of the noise $\sum_{t=1}^T \varepsilon_t^2$ is minimized.

Figure 9 comparing the forecast model with real data in January 2017 for a Finnish city shows good accuracy. The relative standard deviation of ε_t is about 10% for all cities.

To apply the forecast model to generate hourly heat demand data for a city and year, historical hourly temperature data is obtained from [49]. After classifying the hours using weekly rhythm, formula (42) is used to estimate the heat demand. The three linear regression models are applied for different cities based on their sizes. Annual heat demand for the cities are used in order to scale hourly heat demand. It is important to add also proper random noise to the forecast. Without noise, different cities will obtain too coincident heat demand. The random noise is generated so that it has the same relative standard deviation and autocorrelation as the error vectors in the forecasting models fitted for cities. Also, noise for different cities is generated to have the same correlation coefficient as the error vectors between cities.

Figure 9. Hourly heat demand forecast model and historical data of a city in January 2017.

4. Results and discussion

In the following, the main results of all models are presented. All models are solved by LP2 software, an efficient solver for large sparse LP problems [12]. The analysis of the results is implemented in Excel. First, the numerical results of the local CHP optimization model with heat storage are compared with two energy optimization software packages, EnergyPLAN and energyPRO to validate the accuracy of the LP2 solution. Then, the decomposition method developed for long-term problems is illustrated using a small example. After that, the decomposition model is validated by comparison with the integrated model. Finally, the performance of the decomposition method is evaluated by solving different size multi-period models with time horizons ranging from one week (168 hours) to one year (8760 hours) and comparing the solution time with the integrated model.

The input data for each model are introduced at beginning of corresponding section.

4.1 Local optimization solution

A one-week (168 hours) problem is solved using model (2)-(9). The key input parameters are listed in detail in Paper 1. Slightly modified real-life heat demand of a Finnish city is used in the model. For hourly power price, available data from Nordpool [8] is used for Finland in year 2013. Different storage capacities are tested to evaluate the benefit of a heat storage. We also have validated the case study using EnergyPlan and energyPRO.

A 406 MWh heat storage capacity gives outputs displayed in Figure 10. The figure shows the hourly heat storage level. CHP plant produces heat based on heat demand variations to provide heat and after that as much power as can be sold to the market. There are differences in the early time periods for EnergyPLAN, since the software considers initial heat storage level equal to the total capacity. However, fluctuations of LP and energyPRO are similar. The LP model has also the potential to include several heat storage units with different initial levels, which is crucial when the CHP system contains multiple heat storages with different capacities and other parameters. Table 2 presents the optimal values for power and heat production and the objective function by the three models demonstrating the validity of the LP model.

Figure 10. Heat storage level in a week

Table 2. The validation of decision variables

Decision variables	LP	energyPRO	EnergyPLAN
Power production (MW)	5 392	5 392	5 338
Fuel consumption (MW)	19 607	19 607	20 000
Total cost (€)	101 716	101 765	110 000

By using a smaller heat storage equal to 90 MWh, the total cost is 101 994 €, which is only 278€ higher than using the larger storage. This proves the prodigality of the large storage. In investment planning, yearly simulation of the operation is necessary to assess the yearly or lifetime operating costs. The operating costs must then be combined with the investment costs to assess the profitability of a storage of given size or to find out the optimal storage size.

4.2 Hourly decomposition model solution

The decomposition model is illustrated here by a small example. A single hour four-area model is solved by minimizing the combined heat and power production and power transmission costs. The model contains CHP units, one power-only and one HOB unit without storages. Table 3 presents the data used to solve the model. The production units of each area are identical for simplicity. One of the CHP plants has 3 characteristic points and the other two have 2 characteristic points each. Other technical input data include heat and power demand, transmission line capacities and transmission costs.

Table 3. Input data of the plants for each area

Plant	CHP1			CHP2		CHP3	
p (MWh)	3	9.4	12.5	3	11	2	8.4
q (MWh)	10	24.2	38	13	36	6	17
c (€)	315	753.9	1092	420	1155	400	1200
Plant	Power-only				HOB		
Capacity (MW)	150				2695.2		
Efficiency	0.4				0.89		
Fuel price (€/MWh)	21				40		

Table 4. Input data of the plants for each area

Area	1	2	3	4
Power demand (MWh)	5	10	15	20
Heat demand (MWh)	50	60	70	80
Transmission capacity (MW)	10	10	10	10
Transmission cost (€/MWh)	1	1	1	1

Applying parametric analysis on the local hourly model (17)-(20) for each area gives the piecewise linear convex curves determining the optimal cost functions displayed in Figure 11. The curves for different areas are on different levels due to different heat demand in each area. Note that also the number of line segments in the curves differ. The curve of the area with highest heat demand is at highest level, because higher heat production implies higher fuel consumption. The negative slope at the beginning of the cost curves is due to the non-flexible coupling of heat and power in CHP. Low level of power production implies low level of heat production, which means that to satisfy the heat demand the more expensive HOB must also run. For example, in area 4 at point A, CHP produces 8 MWh power which does not allow heat production to cover the 80 MWh heat demand. Thus, the HOB plant must produce 51 MWh heat. At point B, power production is larger and CHP can satisfy the heat demand without the HOB. Therefore, the production cost in point B is lower than at point A. By increasing power production to 175.5 MWh at point C, production costs increase due to maximal 25.5 MWh CHP power production and 150 MWh power-only production.

Figure 11. Optimal production cost as a function of power production in each area

The piecewise linear convex costs functions are then encoded into a network flow problem as described in section 3.5.4. Each line segment results in a production arc from the production node to corresponding area node. The minimum power production in each area $P_{prod,i}^{t,0}$, which is 8MWh for each area, is subtracted from the local power demand and these adjusted demands are set as demand for the area nodes and added as supply to the production node (25). The resulting network flow problem is shown in Figure 12. The figure includes production and transmission arcs with corresponding capacities and costs.

Figure 12. Network flow problem for a single hour.

The optimal solution for the network model is shown in Figure 13. To obtain the actual production at each area, the minimal power production ($P_{prod,i}^{t,0}$) is added to the network solution (production arc flows). As defined in (24) corre-

sponding minimal costs are added to the objective function value of the network problem. The network model gives the objective function value 10102.31 €. Corresponding integrated model gives objective function value 10102.39 €, i.e. the accuracy is six decimal places. Because an optimization model can have multiple (equally good) optimal solutions, the two models may yield different solutions in terms of production in areas and transmission between them, but the objective function value is the same within numerical accuracy.

Figure 13. Solution to the network flow problem.

4.3 Decomposition model validation with integrated model

4.3.1 Decomposition model with power storages

To validate the decomposition model with power storages, it is solved for longer time horizons in Paper 3, and the results are compared with the integrated model (10)-(16) without heat storages. The plant data in Table 3 is used for three areas. Hourly heat and power demand data are scaled to be compatible with the plant capacities in each area. We include a power storage in area 2 with storage capacity 1000 MWh and charge and discharge limits 500 MW. The transmission line capacities are 100 MW with cost 1 €/MWh. The decomposition and integrated models are solved for time horizons from one week (168 hours) to one year (8760 hours). Table 5 reports the objective function values for the two models. The optimal solutions are almost identical with 7 decimal accuracy. We also include for one CHP plant in area 2 ramp constraints for 10% of nominal capacity in both models. Similar accuracy was reached also with ramp constraints. The detailed model specification can be found in Paper 3.

Table 5. Optimal solutions of long-term decomposition and integrated models.

Time horizon (h)	Decomposition (€)	Integrated (€)
168	2155486.8	2155486.9
336	4506361.1	4506361.3
720	10351210	10351210
1440	20225953	20225954
2000	27691057	27691059
2500	34468316	34468318
3600	50561894	50561896
3800	53693839	53693841
4000	56843384	56843387
5000	72570428	72570432
6000	88621237	88621241
7000	102981420	102981420
8760	126451890	126451890

4.3.2 Decomposition model with power and heat storages

Here we add heat storage to both decomposition and integrated models. Based on formulation (33)-(39) and the iterative process (Figure 7), the decomposition method converges to a sub-optimal solution close to the optimum. The details of the verification are presented in Paper 4. Aggregate district heating data for 8 Finnish cities are used for CHP and HOB plants [50]. The forecast model (42) is used to generate simulated hourly heat demand of 2017 for the cities. Hourly power demand from NordPool [8] is scaled down to match the production unit capacities of the cities. Each city corresponds to one area in the model. The models are solved for different size problems including 3, 5, and 8 areas. The selected time horizon of the models is from one week up to one year. For 8 areas, the maximum time horizon that the integrated model can solve is 2100 hours. Figure 14 shows how the solution of the decomposition model improves in each iteration in comparison with integrated optimal solution displayed as a constant line. Each iteration of the decomposition model is shown as two points: the solution after the network model (28)-(31) and after the local multi-period models (33)-(39). The improvement in the first iteration from power transmission model to multi-period local model is higher than during other iterations. The difference between third and fourth iterations is small. Therefore, we consider reaching sufficiently good sub-optimal solution after three iterations. With all problem sizes and small storages, three iterations of the decomposition method made the objective function value converge within 0.02% from the integrated model solution. With large seasonal storages the difference in objective function was 0.1%. Storage size did not affect solution speed or number of iterations needed.

Figure 14. Solutions of the models for 2100 hours for 8 areas (Iteration: nw=after network model, mp=after local multi-period model).

4.4 Solution time for long-term problems

The decomposition methods are developed to speed up optimization and to allow larger models to be solved. The solution time is compared with the integrated model. All test runs are performed in a 64-bit Windows 10 PC with 2.5 GHz Intel Core(TM)-7300U.

4.4.1 Decomposition model with power storages

This decomposition method solves multi-period multi-area problems with power storages and power transmission, but without heat storages. The same three-area problem is solved for different time horizons presented Table 5. To compute the solution time of the decomposition method, the CPU times of the local parametric models (17)–(20) for all areas and for the network model (28)–(31) are added together. To reduce the effect of random variations in CPU time, each test run is performed twice and the average time was reported. Figure 15 shows the solution times of the two models by time horizon. For the decomposition model, the solution time grows by time horizon length much slower than for the integrated model. Up to 720 hours (one month), the integrated model solution is a little faster than decomposition model. With longer time horizons, the decomposition model is faster. For 5 months (3600 hours) and one year (8760 hours) problems, decomposition model respectively is 9 and 30 times faster than integrated model. The solution speed is also tested with ramp constraints included (Paper 3). Ramp constraints are formulated as *side-constraints* to the network model. With ramp-constraints, the results are similar to the CPU times in Figure 15 without ramp constraints.

Figure 15. Solution time comparison of the two models by time horizon.

4.4.2 Decomposition model with power and heat storages

This decomposition method solves multi-period multi-area problems with power and heat storages and power transmission. Table 6 reports the CPU time for solving different size problem. As with the previous method, short-term problems solve faster by the integrated model, and the decomposition method is faster for longer time horizons. For example, with 8 areas, the integrated model solves the 168 h model faster, for the monthly model and for larger models the decomposition method is increasingly faster, and can solve larger models. With the 3 area model, the integrated model is still faster for the monthly model, but increasingly slower for larger models. Also with 3 and 5 areas, the decomposition method can solve larger models than the integrated model.

Table 6. CPU time (s) for decomposition method and integrated model with different time horizons

size	3 areas		5 areas		8 areas	
T (h)	Decomposition	Integrated	Decomposition	Integrated	Decomposition	Integrated
168	6.91	1.33	12.5	3.88	20.71	11.32
720	38.95	27.9	80.74	111.29	164.57	303
2100	187.52	321.05	461.97	1651.97	1098.53	4784
3600	485.68	1554.23	1501.82	8165.93	2722.38	-
3750	543.08	1958.53	1386.51	-	2985.8	-
6400	1541.11	9435.53	3321.63	-		
6700	1742.11	-	3597.13	-		
8760	3280.98	-				

Figure 16 shows the CPU time for the decomposition method and integrated model as function of the number of areas, using the 2100 h model. This was the longest time horizon that could be solved by the integrated model with 8 areas.

Figure 16. Solution time comparison of the two models by number of areas

Numerical results show that decomposition model solves the different size problems for 3 areas 1.7 times, for 5 areas 3.5 times, and for 8 areas 4.3 times faster than integrated model. Figure 17 represents the solution time of models by time horizons for each size problem. Similar to the model without heat storages, by increasing time horizon the decomposition method solves the problem faster than the integrated model. The speed advantage of the decomposition method increases rapidly by the number of periods in each case. This demonstrates the applicability of the decomposition method for longer-term problems.

Figure 17. Solution time comparison by time horizon for different size problems.

4.5 Solution time of network model with simplex algorithm

In the long-term decomposition models, the network model is the largest submodel to solve. Therefore, with large models the network model contributes most to the solution time, and sets limit for how large models can be solved. For this reason, in Paper 2, we compare the speed of solving network models with LP2 sparse simplex algorithm against an efficient Network Simplex algorithm NP2 [47], [51]. NP2 can solve only pure network flow problems. This means that to apply it in the decomposition methods, storages must be assumed to operate without losses. To handle storage losses properly, a generalized network solver would be necessary. Still, tests with pure network problems indicate if a special network solver could benefit the solution of large general network flow problems.

We create artificially power production and transmission network problems of different size. The size of the problems is expressed as $n * m$ where n is the number of nodes and m is the number of production arcs per nodes. The number of nodes and arcs varies from 1 to 50. We produce two sets of prob-

lems: a set where $n = m$, and another set with $n = 30$ nodes and $m \in \{5, 10, 20, 25, 30\}$. The 30-node problems resemble the number of price areas in Europe. The number of production arcs corresponds to different levels of aggregation of local production capacities. To decrease the effect of random variations in CPU time, we run each test three times and reported the average CPU time.

Figure 18 presents the CPU time of network model by NP2 and LP2. When problem size increases, NP2 is increasingly faster than LP2. For larger problems, NP2 is almost 7 times faster than LP2. In addition, with the 30-node problems, NP2 solution time increases more slowly than LP2 by the number of production arcs. This indicates that the number of areas has more impact on the solution time than the number of production arcs. In practice, NP2 can solve any number of production arcs. Both solvers give the same global optimum validating the network solver solution.

Figure 18. Solution time comparison of the network model by size of the problem

4.6 Unit productions

The extreme point formulation and the network model do not contain the power and heat production of individual production units explicitly as decision variables. However, the hourly power and heat production can be computed after optimization using (40) and (41). Hourly power transmission is obtained by (28)-(31). Here, some sample unit productions are presented for the 3-area problem. Figures 19 and 20 display the power and heat production in one area for the fourth week of January. Dashed lines show the level of local power and heat demand.

In figure 19, local CHP with maximum power capacity 22 MW operates both on full and part loads during the week. When power import from the other two areas is cheaper, CHP operates on part load. During low power demand, excess power production is charged into the storage and discharged during high demand. A little power is exported to the other areas.

Figure 19. Power productions of units for one week in one area

Figure 20. Heat productions of units for one week in one area

In figure 20, CHP supplies the main heat demand during the week, while HOB operates during peak time. During low heat demand, excess heat production of CHP is charged into the heat storage, and is discharged to replace either more expensive HOB production, or sometimes CHP production. When the power demand is low in Figure 19, it is beneficial to operate CHP on part load, to import power, and to use the heat storage to balance heat demand.

5. Conclusions and future research

5.1 Conclusions

CHP producing combined heat and power is a sustainable method to produce energy, since it can utilize diverse energy sources efficiently. While heat and power production in pure CHP plants is coupled together, the flexibility of a CHP system can be improved by including separate power and heat production units, heat and power storages, and power transmission between different areas. Such additional units can relax the connection between power and heat production in order to respond to fluctuating and non-coincident demand of heat and power. Such a versatile CHP system is quite complex to operate optimally.

An optimization model is necessary to determine cost-efficient operation of a complex CHP system. The optimization model minimizes total operation costs while satisfying heat and power demand. Depending on the number of production units, storages, number of production areas, and length of planning horizon, the CHP system model can become very large and slow to solve.

This dissertation presented models for economic optimization of long-term multi-area heat and power production with energy storages. While solving the different problems as a single optimization model using a generic solver is in principle possible, many large-scale models do in practice require dedicated modelling and solution techniques. Different modelling and solution techniques were necessary for different CHP system configurations.

A short-term single-area CHP model with heat storage and power trade on the market was formulated as an integrated multi-period model. Different solvers were used to validate the results. Results show that the flexibility of the CHP system is improved by the heat storage relaxing the connection between power and heat production.

Solving longer-term models requires either simplifying assumptions, or various decomposition techniques. Without dynamic constraints (caused by storages or ramping constraints), hourly submodels can be solved separately to obtain the solution for a long-term model. For the separate hourly models, we developed a decomposition method for optimization of combined multi-area power transmission and CHP production. The method includes two phases. In the first phase, parametric analysis is used to determine the hourly production cost as a function of power production. In the second phase, the parametric information is encoded as a network model and solved efficiently using the Network Simplex algorithm. Comparison with the LP2 sparse

simplex algorithm [12] showed that for large problems the Network Simplex is 7 times faster.

Solving complex long-term models with dynamic constraints efficiently requires decomposition techniques. The idea is that solving several smaller sub-models is faster than solving one large model. Sometimes also memory requirements or numerical inaccuracies may prevent solving a large-scale model as an integrated model. For the long-term multi-area CHP production and power transmission problem with power storages, we developed a decomposition technique as extension of the previous parametric decomposition and network encoding method. Here, the network model includes also the storage constraints and possible ramping constraints. Time horizons up to one year could be solved efficiently and with good accuracy, as validated by comparison with an integrated LP model. For smaller problems, the solution time improvement is not significant, but with longer time horizons, the decomposition model solves much faster than the integrated model. For a yearly problem (8760 hours) with 3 areas, the decomposition method is 30 times faster.

The previous decomposition model could not handle heat storages. To solve long-term multi-area CHP problems with power transmission and power and heat storages, a three-phase iterative decomposition method was developed. The first two phases are similar to the previous decomposition model without heat storages. The third phase included local multi-period CHP models to optimize heat storage operation. The method converges rapidly (within 3 iterations) to a sub-optimal solution closer than 0.02% from the true optimum. Comparison between the decomposition method and the integrated model shows that the decomposition model can solve much larger problems than the integrated model. Speedup is also significant for larger problems.

To obtain realistic test data, we applied a forecasting model for heat demand based historical outdoor temperature and social weekly rhythm. Random noise with proper variation and correlation was generated and added to the forecasts for different areas.

To sum up, the presented decomposition methods are fast and applicable for large long-term problems. The solution time tests show that when the problem size increases, the solution time becomes more critical and the integrated model solution time grows much faster than the decomposition method.

5.2 Future research

A generic LP algorithm and a Network Simplex algorithm were used in this study. Future research can involve speeding up optimization time using different special algorithms. The hourly local production models can be solved by Power Simplex algorithm, which is an efficient special algorithm for local CHP production planning problems [12]. The Generalized Network Simplex algorithm [46] can be used for solving the network model when some of the arcs contain losses due to power storages or power transmission. The local long-term CHP problems with power and heat storages could be solved more efficiently using Lagrangian relaxation or related algorithms [52].

The developed methods can be applied for different kinds of analyses. Because the models are based on minimizing the operating costs, they determine the optimal operation of a complex CHP system, which can be compared with the current operation and how it could be altered. Long-term models make it also possible to make projections into the future. Particularly important is to analyse how the increasing amounts of intermittent renewables in the energy system affect CHP systems, and how CHP systems can react to temporally and spatially non-coincident fluctuations in heat and power demand. The models can also be used in investment planning computing the economic benefits of different new technologies, and comparing those to the investment costs. Optimal operative planning can also improve the flexibility of the CHP systems to operate better in a more volatile environment, and to support transition to low-carbon energy systems.

Unit commitment and hydropower optimization were not included in this study. Future research could consider extending the methods to cover these important topics. This research assumed fixed unit commitment. The method should be combined with some algorithm to determine the unit commitment of the plants either heuristically, or using some optimization method. This would allow using the model as a subroutine in unit commitment optimization.

References

- [1] European Commission. 2030 climate & energy framework n.d. https://ec.europa.eu/clima/policies/strategies/2030_en (accessed May 21, 2019).
- [2] Fortum. Combined heat and power (CHP) - more efficient power generation n.d. <https://www.fortum.com/about-us/our-company/our-energy-production/combined-heat-and-power-chp-more-efficient-power-generation> (accessed May 21, 2019).
- [3] COGEN EUROPE. What Is Cogeneration? n.d. <https://www.cogeneurope.eu/> (accessed May 21, 2019).
- [4] COGEN EUROPE. EU Clean Energy Package: “Energy efficiency first” approach a step in the right direction. 2016.
- [5] COGEN EUROPE. Knowledge Centre n.d. <https://www.cogeneurope.eu/knowledge-centre> (accessed May 28, 2019).
- [6] Statistics Finland. Use of renewable energy sources grew in electricity and heat production in 2017 2018. http://www.stat.fi/til/salatuo/2017/salatuo_2017_2018-11-01_tie_001_en.html (accessed May 21, 2019).
- [7] Fortum. Building an efficient Nordic power market. 2016.
- [8] NORD POOL. No Title n.d. <https://www.nordpoolgroup.com/> (accessed May 28, 2019).
- [9] FINGRID Oyj. Electricity market needs fixing – What can we do? Helsinki: 2016.
- [10] Mundaca L, Dalhammar C, Harnesk D. The integrated NORDIC power market and the deployment of renewable energy technologies: Key lessons and potential implications for the future ASEAN integrated power market. *Energy Mark Integr East Asia Renew Energy Its Deploy into Power Syst ERIA Res Proj Rep* 2012--26 2013:25–97.
- [11] Paardekooper S, Lund R, Lund H. Smart Energy Systems. *Energy Storage Options Their Environ. Impact*, 2018.
- [12] Lahdelma R, Hakonen H. An efficient linear programming algorithm for combined heat and power production. *Eur J Oper Res* 2003;148:141–51. doi:10.1016/S0377-2217(02)00460-5.
- [13] Milan C, Bojesen C, Nielsen MP. A cost optimization model for 100% renewable residential energy supply systems. *Energy* 2012;48:118–27.
- [14] Zhang J, Tang H, Chen M. Linear substitute model-based uncertainty analysis of complicated non-linear energy system performance (case study of an adaptive cycle engine). *Appl Energy* 2019;249:87–108.
- [15] Ju L, Zhao R, Tan Q, Lu Y, Tan Q, Wang W. A multi-objective robust

- scheduling model and solution algorithm for a novel virtual power plant connected with power-to-gas and gas storage tank considering uncertainty and demand response. *Appl Energy* 2019;250:1336–55.
- [16] Cui M, Zhang J. Estimating ramping requirements with solar-friendly flexible ramping product in multi-timescale power system operations. *Appl Energy* 2018;225:27–41.
 - [17] Song J, Oh S-D, Yoo Y, Seo S-H, Paek I, Song Y, Song SJ. System design and policy suggestion for reducing electricity curtailment in renewable power systems for remote islands. *Appl Energy* 2018;225:195–208.
 - [18] Rong A, Figueira JR, Lahdelma R. A two phase approach for the bi-objective non-convex combined heat and power production planning problem. *Eur J Oper Res* 2015;245:296–308. doi:10.1016/j.ejor.2015.02.037.
 - [19] Faille D, Fouquet M, Péchiné B, Ahallal S, El Ghaoui L, Pauphilet J. ROBUST PLANNING FOR COMBINED HEAT AND POWER PRODUCTION. *IFAC-PapersOnLine* 2015;48:391–6.
 - [20] Tian X, You F. Carbon-neutral hybrid energy systems with deep water source cooling, biomass heating, and geothermal heat and power. *Appl Energy* 2019;250:413–32.
 - [21] Kelley MT, Pattison RC, Baldick R, Baldea M. An MILP framework for optimizing demand response operation of air separation units. *Appl Energy* 2018;222:951–66.
 - [22] Frangioni A, Gentile C, Lacalandra F. Solving unit commitment problems with general ramp constraints. *Int J Electr Power Energy Syst* 2008;30:316–26.
 - [23] Sashirekha A, Pasupuleti J, Moin NH, Tan CS. Combined heat and power (CHP) economic dispatch solved using Lagrangian relaxation with surrogate subgradient multiplier updates. *Int J Electr Power Energy Syst* 2013;44:421–30. doi:10.1016/j.ijepes.2012.07.038.
 - [24] Wang SJ, Shahidehpour SM, Kirschen DS, Mokhtari S, Irisarri GD. Short-term generation scheduling with transmission and environmental constraints using an augmented Lagrangian relaxation. *IEEE Trans Power Syst* 1995;10:1294–301.
 - [25] Rong A, Figueira JR, Lahdelma R, Grunow M. An improved unit decommitment algorithm for combined heat and power systems. *Eur J Oper Res* 2009;245:552–62. doi:10.1016/j.ejor.2008.02.010.
 - [26] Rong A, Lahdelma R, Grunow M. An effective heuristic for combined heat-and-power production planning with power ramp constraints. *Appl Energy* 2007;84:307–25. doi:10.1016/j.apenergy.2006.07.005.
 - [27] Zakeri B, Virasjoki V, Syri S, Connolly D, Mathiesen B V, Welsch M. Impact of Germany's energy transition on the Nordic power market--A market-based multi-region energy system model. *Energy* 2016;115:1640–62.
 - [28] Salgado F, Pedrero P. Short-term operation planning on cogeneration systems: A survey. *Electr Power Syst Res* 2008;78:835–48. doi:10.1016/j.epsr.2007.06.001.
 - [29] Connolly D, Lund H, Mathiesen BV, Leahy M. A review of computer tools for analysing the integration of renewable energy into various energy systems. *Appl Energy* 2010;87:1059–82.
 - [30] EnergyPLAN. Department of Development and Planning, Aalborg University n.d. <http://www.energyplan.eu/> (accessed May 25, 2018).
 - [31] energyPRO. EMD International A/S n.d. <https://www.emd.dk/energypro/>

(accessed May 25, 2018).

- [32] Wang H, Abdollahi E, Lahdelma R, Jiao W, Zhou Z. Modelling and optimization of the smart hybrid renewable energy for communities (SHREC). *Renew Energy* 2015. doi:10.1016/j.renene.2015.05.036.
- [33] Wang H, Yin W, Abdollahi E, Lahdelma R, Jiao W. Modelling and optimization of CHP based district heating system with renewable energy production and energy storage. *Appl Energy* 2015;159:401–21.
- [34] Østergaard PA, Jantzen J, Marcinkowski HM, Kristensen M. Business and socioeconomic assessment of introducing heat pumps with heat storage in small-scale district heating systems. *Renew Energy* 2019.
- [35] Howells M, Rogner H, Strachan N, Heaps C, Huntington H, Kypreos S, Hughes A, Silveria S, DeCarolis J, Bazillizn M, Roehr A. OSeMOSYS: the open source energy modeling system: an introduction to its ethos, structure and development. *Energy Policy* 2011;39:5850–70.
- [36] Anjo J, Neves D, Silva C, Shivakumar A, Howells M. Modeling the long-term impact of demand response in energy planning: The Portuguese electric system case study. *Energy* 2018;165:456–68.
- [37] Trotter PA, Cooper NJ, Wilson PR. A multi-criteria, long-term energy planning optimisation model with integrated on-grid and off-grid electrification--The case of Uganda. *Appl Energy* 2019;243:288–312.
- [38] Lund H, Münster E. Integrated energy systems and local energy markets. *Energy Policy* 2006;34:1152–60.
- [39] Esteban M, Portugal-Pereira J, Mclellan BC, Bricker J, Farzaneh H, Djalilova N, Keiichi NI, Takagi H, Rober V. 100% renewable energy system in Japan: Smoothing and ancillary services. *Appl Energy* 2018;224:698–707.
- [40] O'Shaughnessy E, Cutler D, Ardani K, Margolis R. Solar plus: Optimization of distributed solar PV through battery storage and dispatchable load in residential buildings. *Appl Energy* 2018;213:11–21.
- [41] Xie C, Hong Y, Ding Y, Li Y, Radcliffe J. An economic feasibility assessment of decoupled energy storage in the UK: With liquid air energy storage as a case study. *Appl Energy* 2018;225:244–57.
- [42] van der Heijde B, Vandermeulen A, Salenbien R, Helsen L. Representative days selection for district energy system optimisation: a solar district heating system with seasonal storage. *Appl Energy* 2019;248:79–94.
- [43] Gadd H, Werner S. Thermal energy storage systems for district heating and cooling. *Adv. Therm. energy storage Syst., Elsevier*; 2015, p. 467–78.
- [44] Fang T. Modelling District Heating and Combined Heat and Power. Aalto University, 2016.
- [45] Pinto G, Abdollahi E, Capozzoli A, Savoldi L, Lahdelma R. Optimization and Multicriteria Evaluation of Carbon-neutral Technologies for District Heating. *Energies* 2019;12:1653.
- [46] Murty KG. Network Programming. Prentice Hall; 1992.
- [47] Bertsekas DP, Scientific A. Network Optimization: Continuous and Discrete Models. INTERFACES-PROVIDENCE-INSTITUTE Manag Sci 1998;28:73–5.
- [48] Fang T, Lahdelma R. Evaluation of a multiple linear regression model and SARIMA model in forecasting heat demand for district heating system. *Appl Energy* 2016;179:544–52.

- [49] FINNISH METEOROLOGICAL INSTITUTE n.d.
https://en.ilmatieteenlaitos.fi/home?p_p_id=locationmenuportlet_WAR_fmiwwwweatherportlets&p_p_lifecycle=1&p_p_state=normal&p_p_mode=view&_locationmenuportlet_WAR_fmiwwwweatherportlets_action=changelocation (accessed May 21, 2019).
- [50] Finnish Energy. District Heating Statistics 2017.
https://energia.fi/ajankohtaista_ja_materiaalipankki/materiaalipankki/kaukolampotilasto.html (accessed May 21, 2019).
- [51] Lahdelma R, Pennanen T, Ruuth S. Comparison of Algorithms for Solving Large Network Flow Problems (s). *Model Identif Control* 1995;309–11.
- [52] Rong A, Lahdelma R, Luh PB. Lagrangian relaxation based algorithm for trigeneration planning with storages. *Eur J Oper Res* 2008;188:240–57.

ISBN 978-952-60-8743-6 (printed)
ISBN 978-952-60-8744-3 (pdf)
ISSN 1799-4934 (printed)
ISSN 1799-4942 (pdf)

Aalto University
School of Engineering
Department of Mechanical Engineering
www.aalto.fi

**BUSINESS +
ECONOMY**

**ART +
DESIGN +
ARCHITECTURE**

**SCIENCE +
TECHNOLOGY**

CROSSOVER

**DOCTORAL
DISSERTATIONS**